

No. DY201020



中国认可
国际互认
检测
TESTING
CNAS L0153

TEST REPORT

Name of product Metal Oxide Surge Arresters Without Gaps

Type Specification YH10W-36

Applicant SHIJIAZHUANG YONGRUI ELECTRICAL EQUIPMENT CO., LTD.

Testing category Type Test



广东产品质量监督检验研究院

Guangdong Testing Institute of Product Quality Supervision

检测报告

TEST REPORT

Page 1 of 58

产品名称 Name of product	Metal Oxide Surge Arresters Without Gaps	生产日期/有效日期 Date of manufacturing/ expiry	— / —
型号、规格、商标、等级 Type, Specification, Trade mark, Class	YH10W-36	编号/批号 Batch No.	— / —
受检单位 Inspected unit	—	检测/抽样单号 No. of testing/sampling plan	YGY20/000875/ —
受检单位 地址 Address of inspected unit	—	检测类别 Testing category	Type Test
委托单位(申请人) Applicant	SHIJIAZHUANG YONGRUI ELECTRICAL EQUIPMENT CO., LTD.	抽样地点 Location of sampling	—
生产单位 Factory	SHIJIAZHUANG YONGRUI ELECTRICAL EQUIPMENT CO., LTD.	抽样基数 Basic quantity of sampling	—
生产单位 地址 Address of factory	No.268, Xingye East Street, Xinji Economic Development Zone, Hebei, China	来样方式 Way of sample incoming 送/抽样者 Personnel performing sending/sampling	Customer Sampling sending (Wu Pin)
样品数量 Quantity of sample	See notes	到/抽样日期 Date of receipt of sample/ sampling	2020-04-22/ —
样品状态 Status of sample	Good condition	检测日期 Date(s) of performance of tests	2020-04-22 to 2020-07-29
检测依据 Testing reference	IEC 60099-4: 2014 Surge arresters - Part 4: Metal-oxide surge arresters without gaps for a.c. systems		
判定依据 Judgment reference	Consignor's technical condition		
检测结论 Conclusion	Type tests were carried out in accordance with the requirements of testing reference and judgement reference. The samples were found to comply with the above testing reference and the basis of judgement.	 检验检测专用章 Official testing stamp of the institute 签发日期 Date of issue 2020-07-29 (D1)	
备注 Notes	Arrester: 1#~12#, Composite housing: W ₁ ~W ₃ , Section of an arrester: B ₁ ~B ₁₅ , MO resistance: R ₁ ~R ₄₀ , Arrester disconnector: T ₁ ~T ₅₀ , Specimens of shed and housing material: Y ₁ ~Y ₃ .		

批准:

Approved by:

审核:

Reviewed by:

主检:

Tested by:

检测报告

TEST REPORT

Page 2 of 58

Catalogue	
Contents	Page
First page	1
Catalogue	2
Test items summary	3-5
Main technical data assigned by the manufacturer	6
Insulation withstand tests on the arrester housing	7
Residual voltage test	8
Test to verify long term stability under continuous operating voltage	9
Repetitive charge transfer withstand test	10
Heat dissipation behaviour verification of test sample	11-12
Operating duty test	13
Power-frequency voltage versus time test	14
Arrester disconnector test	15-18
Short-circuit tests	19
Bending moment test	20-21
Seal leak rate test	22
Weather ageing test	23
Annex	24-57
Notions	58

检测报告

TEST REPORT

Page 3 of 58

Test items summary					
Item	Test items	Specified values		Measured values	Conclusions
		Standards (Consigner's technology condition)			
1	Insulation withstand tests on the arrester housing	Lightning impulse test	Specified voltage (kV):170 Atmospheric correction factor Kt: 1.001 Corrected voltage (kV): 170.2 Application number: 15 times for each polarity. During the test, no internal disruptive discharges shall occur and if the number of the external disruptive discharges does not exceed two in each series of 15 impulses.	W ₁ 170.0 1.001 +168.32~+171.80/ -169.40~-172.31 15 times for each polarity	Pass
		Power-frequency voltage test	Wet conditions test Specified voltage (kV):70 Atmospheric correction factor Kt: 0.996 Corrected voltage (kV):69.7 Duration (s):60 No flashover or puncture shall occur during the test.	70.0 0.996 69.7 60 No flashover or puncture/ Complied	
2	Residual voltage test	Lightning impulse residual voltage test	Lightning impulse current (8/20μs) (kA): <u>10</u> Residual voltage (kV): <u>≤103</u>	R ₁ R ₂ R ₃ 101.14	Pass
		Steep current impulse residual voltage test	Steep impulse current (1μs) (kA): <u>10</u> Residual voltage (kV): <u>≤123</u>	119.57	
3	Test to verify long term stability under continuous operating voltage	See page 9		B ₁ B ₂ B ₃ See page 9	Pass
4	Repetitive charge transfer withstand test	Repetitive charge transfer rating, Qrs (C): 0.4		R _{4~R₁₃} See page 10	Pass
5	Heat dissipation behaviour verification of test sample	See page 11~12		1 [#] B ₄ Heat dissipation behaviour curve See page 12	/

Note: In conclusions, "/" means provide test data only.

检测报告

TEST REPORT

Page 4 of 58

Test items summary				
Item	Test items	Specified values	Measured values	Conclusions
		Standards (Consigner's technology condition)		
6	Operating duty test	4/10μs Peak current (kA):100 Impact times:1 Thermal charge transfer rating Qth (C):1.1 Thermal recovery has been demonstrated; No physical damage is evident; U_{res} changed ratio (%): $\leq\pm 5$	B _{5~B₇} See page 13	Pass
7	Power-frequency voltage versus time test	See page 14	B _{8~B₁₂} See page 14	Pass
8	Arrester disconnector test	Repetitive charge transfer withstand test	Repetitive charge transfer rating, Qrs (C):0.4	T _{1~T₃} See page 15
		Operating duty test	4/10μs Peak current (kA):100 Impact times:1 Thermal charge transfer rating, Qth (C):1.1 The disconnectors shall withstand the tests without operating.	B _{13~B₁₅+T₆} See page 16
		Time versus current test	See page 17	T _{7~T₂₁} See page 17
		Temperature cycling and seal pumping test	See page 17~18	T _{22~T₃₁} See page 17~18
9	Short-circuit tests	See page 19	2 [#] ~5 [#] See page 19	/
10	Bending moment test	See page 20~21	6 [#] ~8 [#] See page 20~21	Pass

Note: In conclusions, "/" means provide test data only.

检测报告

TEST REPORT

Page 5 of 58

Test items summary				
Item	Test items	Specified values	Measured values	Conclu- sions
		Standards (Consigner's technology condition)		
11	Seal leak rate test	Seal leak rate test (Hot water immersion) Water temperature (°C):— Environment temperature (°C): \geq 5 Temperature difference (K): 45 ± 5 Immersion duration (min): ≥30 Duration of test, there should be no continuous bubbles produced.	9# 77.0 32.0 45 35 No continuous bubbles produced	Pass
12	Weather ageing test	Salt fog test See page 23	10# See page 23	Pass
		UV light test See page 23	Y ₁ Y ₂ Y ₃ See page 23	

检测报告

TEST REPORT

Main technical data assigned by the manufacturer

Type: YH10W-36

Name of sample: Metal Oxide Surge Arresters Without Gaps

1)arrester

- a) Designation: DH
- b) Rated voltage, Ur (kV):36
- c) Continuous operating voltage, Uc (kV):29
- d) Nominal discharge current, In (kA):10
- e) Reference current (resistive current peak), (mA):1
- f) Bending moment (N):SSL=785 SLL=314
- g) Repetitive charge transfer rating, Qrs (C):0.4
- h) Thermal charge transfer rating, Qth (C):1.1
- i) Rated Short-circuit current, Is (kA):16
- g) Residual voltage:

Lightning impulse residual voltage at I_n (kV): \leq 103

Steep current impulse residual voltage at I_n (kV): \leq 123

2) MO resistance

- a) Specification (mm): Φ 38×24

3) Composite housing

- a) Insulation withstand of the arrester housing:

Rated power frequency withstand voltage (kV):70

Rated lightning impulse withstand voltage (kV):170

- b) Housing material and color: Grey silicone rubber

检测报告

TEST REPORT

Test items and result

1 Insulation withstand tests on the arrester housing

1.1 Lightning impulse test

Test date: April 27, 2020

Humidity: 56%; Ambient temperature: 26.1°C; Atmospheric pressure: 100.4kPa

Minimum discharge path of sample: L = 370 (mm)

Specified value: 170 kV Atmospheric correction factor: K_t = 1.001 Corrected value: 170.2 kV

No.	Voltage polarity	Test voltage (kV)	Application number	Test result
W ₁	+	+168.32~+171.80	15	No internal disruptive discharges /Complied
	-	-169.40~-172.31	15	No internal disruptive discharges /Complied

Note: No internal disruptive discharges occur during the test.

1.2 Power-frequency voltage test

Test date: April 27, 2020

Humidity: 56%; Ambient temperature: 26.4°C; Atmospheric pressure: 100.3kPa

Conductivity of water: 99 ($\mu\text{S}/\text{cm}$)

Precipitation of vertical component: 1.3 (mm/min)

Precipitation of horizontal component: 1.3 (mm/min)

Minimum discharge path of sample: L = 370 (mm)

Specified value: 70 kV Atmospheric correction factor: K_t = 0.996 Corrected value: 69.7 kV

No.	Test voltage (kV)	Duration (s)	Application number	Test result
W ₁	69.7	60	1	No flashover or puncture/ Complied

Note: No flashover or puncture shall occur during the test.

Conclusions: Pass

检测报告

TEST REPORT

Page 8 of 58

2 Residual voltage test

Test date: April 28, 2020

Humidity: 62%; Ambient temperature: 29.0°C; Atmospheric pressure: 100.3kPa

2.1 Lightning impulse residual voltage test

No.		R ₁	R ₂	R ₃
29.0 °C, U _{ref} (kV)	kV	3.69	3.66	3.68
8/20μs, Residual voltage at 5kA U _{5kA}	kVp	8.55	8.43	8.51
8/20μs, Residual voltage at 10kA U _{10kA}	kVp	9.35	9.25	9.33
8/20μs, Residual voltage at 20kA U _{20kA}	kVp	10.33	10.30	10.36
Residual voltage of arrester at 10kA	Scale factor	-	10.81	10.90
	8/20μs 10kA	kVp	101.07	100.82
	Requirements	kVp	≤103	

R₁~R₃ Lightning impulse residual voltage test oscillogram No.: L20-GY0875-S01~L20-GY0875-S03.

2.2 Steep current impulse residual voltage test

No.		R ₁	R ₂	R ₃
29.0 °C, U _{ref} (kV)	kV	3.69	3.66	3.68
1μs, Residual voltage at 10kA U _{10kA}	kVp	10.57	10.52	10.55
Residual voltage of arrester at 10kA	Scale factor	-	10.81	10.90
	1μs 10kA	kVp	114.26	114.67
Maximum steep current impulse residual voltage excluding inductive voltage contribution	kVp	114.67		
Inductive voltage U _L	kVp	4.90		
Maximum steep current impulse residual voltage including inductive voltage contribution	kVp	119.57		

Note: A steep current impulse as described above shall be applied to a metal block having the same dimensions as the resistor samples being tested. The peak voltage on the metal block is 0.1(kV), $0.1 / 10.52 = 0.9\% \leq 2\%$, No correction required.

R₁~R₃ Steep current impulse residual voltage test oscillogram No.: L20-GY0875-S04~L20-GY0875-S06.

Conclusions: Pass

检测报告

TEST REPORT

3 Test to verify long term stability under continuous operating voltage

Test date: April 27, 2020~June 8, 2020

Humidity: (53~71)%; Ambient temperature: (26.1~32.1)°C; Atmospheric pressure: (100.4~101.3)kPa
 Arrester technical data: $U_r = 36$ kV, $U_c = 29$ kV, Arrester length = 0.490(m).

Applied voltage $U_{ct} = U_c(1+0.15H)$ Test duration: 1000^{+100}_0 h; Actual duration: 1004h; Test temperature: $115^{\circ}\text{C} \pm 4\text{K}$

No.	B ₁	B ₂	B ₃
<u>27.4</u> °C, U_{ref} (kV) (kV)	3.68	3.68	3.68
U_c (kV)	2.96	2.96	2.96
U_{ct} (kV)	3.18	3.18	3.18
P_{start} (W)	0.987	0.974	0.981
P_{min} (W)	0.844	0.836	0.838
P_{end} (W)	0.910	0.904	0.908

Any increase of power losses from P_{min} , is not greater than 1,3 times P_{min} during the remaining test period,
 all measurements of power losses throughout the ageing period, including the final measurement, P_{end} ,
is not greater than 1,1 times P_{start} .

Conclusions: Pass

检测报告

TEST REPORT

Page 10 of 58

4 Repetitive charge transfer withstand test

Test date: April 29, 2020~April 30, 2020

Humidity: (54~62)%; Ambient temperature: (26.4~29.2)°C; Atmospheric pressure: (100.3~100.7)kPa

No.	R ₄	R ₅	R ₆	R ₇	R ₈	R ₉	R ₁₀	R ₁₁	R ₁₂	R ₁₃	Requirements
27.4 °C,U _{ref} (kV)	3.69	3.58	3.66	3.66	3.67	3.60	3.62	3.70	3.68	3.72	/
8/20μs,U _{res} (kV)	9.37	9.23	9.34	9.33	9.33	9.24	9.27	9.42	9.34	9.46	/
Q _{rs} (C)	1st	0.46	0.46	0.46	0.46	0.46	0.45	0.46	0.46	0.45	<u>0.4(110% ~120%)</u>
	2st	0.45	0.44	0.44	0.45	0.45	0.46	0.45	0.45	0.44	
	3st	0.45	0.45	0.45	0.46	0.46	0.45	0.44	0.45	0.45	
	4st	0.45	0.45	0.44	0.45	0.44	0.45	0.45	0.45	0.46	
	5st	0.44	0.44	0.46	0.44	0.45	0.46	0.46	0.44	0.45	
	6st	0.45	0.44	0.44	0.45	0.44	0.45	0.45	0.46	0.46	
	7st	0.45	0.45	0.45	0.46	0.45	0.45	0.45	0.44	0.46	
	8st	0.44	0.45	0.44	0.45	0.46	0.45	0.45	0.46	0.44	
	9st	0.46	0.44	0.45	0.44	0.45	0.46	0.46	0.45	0.46	
	10st	0.44	0.46	0.46	0.45	0.45	0.45	0.44	0.44	0.46	
	11st	0.45	0.45	0.45	0.44	0.44	0.45	0.44	0.45	0.45	
	12st	0.45	0.44	0.45	0.45	0.45	0.45	0.44	0.45	0.45	
	13st	0.46	0.46	0.44	0.46	0.45	0.44	0.46	0.46	0.44	
	14st	0.45	0.44	0.46	0.46	0.44	0.46	0.46	0.45	0.44	
	15st	0.44	0.45	0.45	0.45	0.45	0.44	0.45	0.45	0.46	
	16st	0.46	0.45	0.44	0.44	0.44	0.44	0.44	0.44	0.45	
	17st	0.44	0.45	0.46	0.46	0.44	0.45	0.45	0.46	0.44	
	18st	0.45	0.46	0.45	0.45	0.45	0.46	0.45	0.45	0.45	
	19st	0.44	0.45	0.45	0.44	0.46	0.45	0.44	0.45	0.46	
	20st	0.45	0.47	0.45	0.45	0.46	0.45	0.46	0.46	0.45	
28.1 °C,U _{ref} (kV)	3.60	3.51	3.59	3.58	3.59	3.52	3.55	3.61	3.59	3.64	/
U _{ref} changed ratio (%)	-2.44	-1.96	-1.91	-2.19	-2.18	-2.22	-1.93	-2.43	-2.45	-2.15	≤±5
8/20μs,U _{res} (kV)	9.55	9.47	9.51	9.49	9.50	9.48	9.49	9.53	9.51	9.62	/
U _{res} changed ratio (%)	+1.88	+2.53	+1.79	+1.69	+1.79	+2.53	+2.32	+1.15	+1.79	+1.66	≤±5
Application a current impulse 8/20 μs (kA)	5.72	5.70	5.77	5.71	5.72	5.69	5.73	5.74	5.76	5.71	<u>5.67 (MO resistors cross area: 11.34cm²)</u>
Visual inspection	No damage	No damage	No damage	No damage	No mechanical damage						

R₄~R₁₃ 1st&20st test oscillogram No.: L20-GY0875-S07~L20-GY0875-S26.

Conclusions: Pass

检测报告

TEST REPORT

Page 11 of 58

5 Heat dissipation behaviour verification of test sample

Test date: May 11, 2020

Humidity: 63%; Ambient temperature: 29.1°C; Atmospheric pressure: 100.3kPa


No.	1#	B ₄
Measuring point location	1/3 of the section from the top	1/3 of the section from the top
Heated time(min)	55	55
Maximum heating temperature T ₀ (°C)	143	142
Average ambient temperature during the test T _A (°C)	28.1	28.1
Cooling time curve	See page 12	
The relative over temperature (T _{rel}) time curve	See page 12	
At any time, the section of arrester relative overtemperature value higher than the complete arrester.		

Note: The relative over temperature T_{rel}= (T-T_A) / (T₀-T_A), The corresponding temperature added: k×(T₀-T_A).


检测报告

TEST REPORT

Page 12 of 58



Arrester&section of arrester cooling time curve

Arrester§ion of arrester relative over temperature (T_{rel}) time curve

Conclusions: /

检测报告

TEST REPORT

6 Operating duty test

Test date: May 12, 2020

Humidity: 64%; Ambient temperature: 27.8°C; Atmospheric pressure: 100.1kPa

No.	B ₅	B ₆	B ₇
27.8 °C, U _{ref} (kV)	3.68	3.68	3.68
8/20μs, U _{res} (kV)	9.36	9.34	9.33
U _r (kV)	3.68	3.68	3.68
U _c (kV)	2.96	2.96	2.96
4/10μs High current impulse	1st impulse current (kA)	101.451	100.687
			101.124

Preheated to 60 °C

8/20μs current impulse, Q _{th}	1st impulse current (C)	0.55	0.56	0.58
	2st impulse current (C)	0.56	0.58	0.58

After 66 ms applied a power frequency voltage

Application U _r (kV)	3.68	3.68	3.68
Duration (s)	10	10	10
Application U _c (kV)	2.96	2.96	2.96
Duration (min)	30	30	30
Visual inspection	No damage	No damage	No damage
8/20μs, U _{res} (kV)	9.43	9.41	9.39
U _{res} changed ratio (%)≤±5	+0.75	+0.75	+0.64

Note: 1) Thermal recovery has been demonstrated;

2) No physical damage is evident.

B₅~B₇ test oscillogram No.: L20-GY0875-S27~L20-GY0875-S35.

Conclusions: Pass

检测报告

TEST REPORT

Page 14 of 58

7 Power-frequency voltage versus time test

Test date: May 13, 2020

Humidity: 61%; Ambient temperature: 28.6°C; Atmospheric pressure: 100.2kPa

No.	B ₈	B ₉	B ₁₀	B ₁₁	B ₁₂
28.6 °C, U _{ref} (kV)	3.67	3.68	3.68	3.64	3.66
8/20μs, U _{res} (kV)	9.36	9.37	9.37	9.33	9.34
U _r (kV)	3.67	3.68	3.68	3.64	3.66
U _c (kV)	2.96	2.96	2.96	2.92	2.93
Preheated to 60 °C					
8/20μs current impulse, Q _{th}	1st impulse current (C)	0.56	0.57	0.56	0.57
	2st impulse current (C)	0.57	0.57	0.57	0.57
After 66 ms applied a power frequency voltage					
Applied power frequency overvoltage duration	Applied power frequency overvoltage (kV)	4.40	4.23	4.05	3.64
	Application times of U _r	1.20	1.15	1.10	1.00
	Duration	0.1s	1.1s	10.1s	1h
	Application U _c (kV)	2.96	2.96	2.96	2.92
	Duration (min)	30	30	30	30
Visual inspection		No damage	No damage	No damage	No damage
8/20μs, U _{res} (kV)		9.44	9.46	9.45	9.41
U _{res} changed ratio (%)≤±5		+0.85	+0.96	+0.85	+0.86
					+0.96

Note: 1) Thermal recovery has been demonstrated;

2) No physical damage is evident.

B8~B10 test oscillogram No.: L20-GY0875-S36~L20-GY0875-S45.

Conclusions: Pass

检测报告

TEST REPORT

Page 15 of 58

8 Arrester disconnector test

Test date: May 12, 2020~May 15, 2020

Humidity: (61~69)%; Ambient temperature: (27.0~30.6)°C; Atmospheric pressure: (100.3~100.7)kPa

8.1 Repetitive charge transfer withstand test

	No.	T ₁	T ₂	T ₃	Requirements
Q _{rs} (C)	1st	0.46	0.46	0.45	<u>0.4(110%~120%)</u>
	2st	0.44	0.45	0.45	
	3st	0.45	0.45	0.46	
	4st	0.45	0.44	0.45	
	5st	0.45	0.46	0.44	
	6st	0.44	0.44	0.44	
	7st	0.46	0.45	0.45	
	8st	0.44	0.45	0.45	
	9st	0.45	0.45	0.44	
	10st	0.45	0.44	0.45	
	11st	0.44	0.45	0.44	
	12st	0.44	0.44	0.45	
	13st	0.46	0.45	0.45	
	14st	0.45	0.45	0.46	
	15st	0.45	0.46	0.45	
	16st	0.45	0.45	0.45	
	17st	0.44	0.45	0.45	
	18st	0.45	0.44	0.44	
	19st	0.44	0.44	0.45	
	20st	0.45	0.45	0.45	
Visual inspection		Without operation	Without operation	Without operation	Without operation
Disconnecter operation at 20A (rms)					
Visual inspection		Successful operation	Successful operation	Successful operation	Shall successful operation

Note: 1) The disconnectors shall withstand the tests without operating.

2) Each of the samples used for the tests successfully operates in a subsequent test of operation when conducting a current of 20 A rms symmetrical.

T₁~T₃ 1st&20st test oscillogram No.: L20-GY0875-S46~L20-GY0875-S51.

检测报告

TEST REPORT

8.2 Operating duty test

No.	B ₁₃ +T ₄	B ₁₄ +T ₅	B ₁₅ +T ₆
28.7 °C, U _{ref} (kV)	3.68	3.68	3.68
8/20μs, U _{res} (kV)	9.37	9.35	9.36
U _r (kV)	3.68	3.68	3.68
U _c (kV)	2.96	2.96	2.96
4/10μs High current impulse	1st impulse current (kA)	100.457	100.341
Preheated to 60 °C			
8/20μs current impulse, Q _{th}	1st impulse current (C)	0.58	0.58
	2st impulse current (C)	0.56	0.58
After 66 ms applied a power frequency voltage			
Application U _r (kV)	3.68	3.68	3.68
Duration (s)	10	10	10
Application U _c (kV)	2.96	2.96	2.96
Duration (min)	30	30	30
Visual inspection	Without operation	Without operation	Without operation
8/20μs, U _{res} (kV)	9.44	9.43	9.41
U _{res} changed ratio (%) $\leq\pm 5$	+0.75	+0.86	+0.53
Disconnecter operation at 20A (rms)			
Visual inspection	Successful operation	Successful operation	Successful operation

Note: 1) The sample disconnector in series with a test sample section of the arrester.

2) The disconnectors shall withstand the tests without operating.

3) Each of the samples used for the tests successfully operates in a subsequent test of operation when conducting a current of 20 A rms symmetrical.

B₁₂+T₄ ~ B₁₄+T₆ test oscillogram No.: L20-GY0875-S52 ~ L20-GY0875-S60.

检测报告

TEST REPORT

8.3 Time versus current test

No.	Requirements (rms) (A)	Measurements (rms) (A)	Operation time(ms)	Maximum operation time (ms)	Test results
			Measurements		
T ₇	20A±10%	20.3	1831	3059	Successful operation
T ₈		20.1	2970		Successful operation
T ₉		20.1	3059		Successful operation
T ₁₀		20.2	2493		Successful operation
T ₁₁		20.3	1804		Successful operation
T ₁₂	200A±10%	191	497	501	Successful operation
T ₁₃		189	457		Successful operation
T ₁₄		194	253		Successful operation
T ₁₅		191	501		Successful operation
T ₁₆		192	497		Successful operation
T ₁₇	800A±10%	770	60	60	Successful operation
T ₁₈		765	42		Successful operation
T ₁₉		767	42		Successful operation
T ₂₀		790	32		Successful operation
T ₂₁		770	41		Successful operation

8.4 Temperature cycling and seal pumping test

8.4.1 Temperature cycling

Test items	Requirements	No.
		T ₂₂ ~T ₃₁
Hot period temperature (°C)	40~70	50.0
Cold period temperature (°C)	At least 85 K below the hot period, the lowest temperature shall not be lower than -50°C	-35.0
Duration of each temperature (h)	3	3
Temperature change gradient (K/min)	1	1.0
Number of cycles	10	10

检测报告

TEST REPORT

Page 18 of 58

8.4.2 Seal pumping test

Test items	Requirements	No.
		T _{22~T₃₁}
Hot period temperature(°C)	60±3	60.0
Duration(h)	≥1	1
Cold water temperature(°C)	4±3	4.0
Duration(h)	≥2	2
The transfer time(min)	≤5	3
Temperature number of cycles	10	10

8.4.3 Temperature cycling and seal pumping test evaluation

Opened the arrester disconnectors for visual inspection, no moisture were founded within the each test samples.

Conclusions: Pass

检测报告

TEST REPORT

9 Short-circuit tests

Test date: June 30, 2020 ~ July 3, 2020

9.1 Contents, methods, circuits and prospective of capacitive current switching tests

Test items	Test times	Test voltage(kV)	Short-circuit current (kA)		Duration (s)	Note
			R.M.S.	Peak		
Rated-current short-circuit test	1	< 77 % of Ur	16	40		—
Reduced-current short-circuit test	1	< 77 % of Ur	6	8.49	≥0.2	—
Reduced-current short-circuit test	1	< 77 % of Ur	3	4.25		—
Low-current short-circuit test	1	< 77 % of Ur	0.6	0.85	1	—

9.2 Short-circuit tests

No.	Test items	Test oscillograms No.	Test voltage (kV)	Short-circuit current (kA)		Duration (s)
				R.M.S	Peak	
2#	Rated-current test	D20G-GY0875-S1	12.0	16.9	40.2	0.210
3#	Reduced-current test	D20D-GY0875-S1	10.1	5.81	9.61	0.204
4#	Reduced-current test	D20D-GY0875-S2	10.2	3.02	5.57	0.204
5#	Low-current test	D20D-GY0875-S3	10.1	0.606	1.30	1.000

9.3 Visual inspection

Evaluation of test results	2#	3#	4#	5#
a)No violent shattering. Structural failure of sample is permitted as long as criteria b) and c) are met.	Complied	Complied	Complied	Complied
b)No parts of sample shall be allowed to be found outside the enclosure,except for	Complied	Complied	Complied	Complied
—fragments,less than 60 g each,of ceramic material such as MO resistors of porcelain; —pressure relief vent covers and diaphragms; —soft parts of polymeric materials.	—	—	—	—
c)The arrester shall be able to self-extinguish open flames within 2 min after the end of the test.Any ejected part(in or out of the enclosure)must also self-extinguish open flames within 2 min.	Complied	Complied	Complied	Complied

Note:Short-circuit tests photos: page 28~31.

Conclusions: Pass

检测报告

TEST REPORT

10 Bending moment test

Test date: May 15, 2020

Humidity: 65%; Ambient temperature: 29.4 °C; Atmospheric pressure: 100.6kPa

10.1 Sample preparation

No.	6#	7#	8#
Watt losses measured at U_c (mW)	1236	1244	1252
Internal partial discharge at $1.05U_c$ (pC) ≤ 10	2.6	2.8	2.4
U_{res} at 1.0 In (kV)	100.46	100.72	100.30

10.2 Bending moment test

No.	Application SSL (N)	Duration (s)	Maximum deflection (mm)	Residual deflection (mm)	Visual inspection
6#	800	70	64	14.6	No damage
7#	800	70	67	15.7	No damage
Requirements	$785_0^{+5\%}$	60 ~ 90	/	/	No visible damage

10.3 Mechanical/thermal preconditioning

10.3.1 Terminal torque preconditioning

No.	Torque(N·M)	Duration(s)	Visual inspection
8#	—	—	—
Requirements	—	—	—

Note: No torque requirements.

10.3.2 Thermo-mechanical and thermal preconditioning

No.	Test temperature (°C)	Duration (h)	Application	
			Load direction (°)	SLL (N)
8#	+60	16	0	320
	-25	16	180	320
	+45	16	270	320
	-40	16	90	320
Requirements	+60~ -25 ~ +45~ -40	16	0~360	$314_0^{+5\%}$

检测报告

TEST REPORT

10.4 Water immersion test and Bending moment Test evaluation

The test samples shall be kept immersed in a vessel, in boiling deionised water with 1 kg/m³ of NaCl, for 42 h.

No.	6 [#]	7 [#]	8 [#]
Boiling duration (h)	42	42	42
Verification tests (h)≤8	8	8	8
Watt losses measured at U _c (mW)	1266	1270	1283
Watt losses changed (mW/kV)≤20	1.03	0.90	1.07
Watt losses changed ratio (%):≤±5	+2.43	+2.09	+2.48
Internal partial discharge at 1.05U _C (pC):≤10	2.9	3.2	3.4
U _{res} at 1.0 In (kV)	100.87	101.21	100.94
U _{res} at 1.0 In changed ratio between sample preparation (%):≤±5	+0.4	+0.5	+0.6
30.6 °C, U _{ref} (kV)	39.26	39.44	39.10
U _{res} at In (kV)	100.86	101.24	100.96
U _{res} at In (kV)	100.98	101.37	101.10
U _{res} changed ratio (%):≤±2	+0.1	+0.1	+0.1
31.0 °C, U _{ref} (kV)	39.41	39.52	39.23
U _{ref} changed ratio (%):≤±2	+0.4	+0.2	+0.3

Conclusions: Pass

检测报告

TEST REPORT

Page 22 of 58

11 Seal leak rate test

Test date: May 15, 2020

Humidity: 59%; Ambient temperature: 32.0°C; Atmospheric pressure: 100.3kPa

Hot water immersion

No.	9#
Water temperature(°C)	77.0
Environment temperature(°C)≥5	32.0
Temperature difference(K)45±5	45
Immersion duration(min)≥30	35
Should no continuous bubbles produced	No continuous bubbles produced

Conclusions: Pass

检测报告

TEST REPORT

Page 23 of 58

12 Weather ageing test

Test date: April 25, 2020~ June 8, 2020

Humidity: (49~73)%; Ambient temperature: (26.9~31.0)°C; Atmospheric pressure: (100.1~101.4)kPa

12.1 Salt fog test

No.	10 [#]
<u>27.8</u> °C, U _{ref} (kV)	39.6
Internal partial discharge at 1.05U _C (pC)≤10	2.6
Water flow rate (l/h/m ³) 0.4±0.1	0.41
Temperature (°C)20±5	21.0
NaCl content of water (kg/m ³)1~10	2.0
Application U _c (kV)	29.0
Duration (h)≥1000	1004
Visual inspection	No tracking occurs
	Erosion does not occur through the entire thickness of any shed or other part of the external coating up to the next layer of material
	The sheds and housing are not punctured
Internal partial discharge at 1.05U _C (pC)≤10	4.7
<u>28.6</u> °C, U _{ref} (kV)	39.3
U _{ref} changed ratio (%)≤±5%	-0.8

12.2 UV light test

Xenon-arc methods

No.	Y ₁	Y ₂	Y ₃
Without dark periods, standard spray cycle, black-standard/black panel temperatures of 65 °C, an irradiance of around 550 W/m ² .			
Duration (h)≥1000	1007	1007	1007
Visual inspection	Markings on shed or housing material shall be legible	Complied	Complied
	Surface degradations such as cracks and raised areas are not permitted	Complied	Complied
	In case of doubt concerning such degradation, two surface roughness measurements, Rz shall not exceed 0,1 mm.	—	—

Conclusions: Pass

检测报告

TEST REPORT

Annex

1. Drawing

YH10W-36 Metal Oxide Surge Arrester Without Gaps Drawing

2. Tested object photos

21 photos

3. Test circuit

Short-circuit tests circuit: D20G-GY0875-YLT1;

(4/10μs)High current impulse withstand and Residual voltage tests circuit:D20-GY0875-YLT1;

(1.2/50μs)lightning impulse withstand voltage test circuit:D20-GY0875-YLT2;

4. Tests oscillograms

Short-circuit test(16000A)oscillograms:D20G-GY0875-S1;

Short-circuit test(6000A) oscillograms:D20D-GY0875-S1;

Short-circuit test(3000A) oscillograms:D20D-GY0875-S2;

Short-circuit test(600A) oscillograms:D20D-GY0875-S3;

Lightning impulse residual voltage test oscillograms:L20-GY0875-S01~L20-GY0875-S03;

Steep current impulse residual voltage test oscillograms:L20-GY0875-S04~L20-GY0875-S06;

Repetitive charge transfer withstand test Typical oscillograms:L20-GY0875-S07~L20-GY0875-S26;

Operating duty test oscillograms :L20-GY0875-S27~L20-GY0875-S35;

Power-frequency voltage versus time test oscillograms:L20-GY0875-S36~L20-GY0875-S45;

Disconnecter repetitive charge transfer withstand test Typical oscillograms:

L20-GY0875-S46~L20-GY0875-S51;

Disconnecter operating duty test oscillograms :L20-GY0875-S52~L20-GY0875-S60;

Lightning impulse residual voltage test oscillograms:L20-GY0875-S61~L20-GY0875-S72.

检测报告

TEST REPORT

Page 25 of 58

Drawing	YH10W-36 Metal Oxide Surge Arrester Without Gaps


检测报告

TEST REPORT

Page 26 of 58

Tested object photos


Arrester:



Section of an arrester:



Arrester disconnector:




检测报告

TEST REPORT

Page 27 of 58

Tested object photos

Composite housing:



MO resistance:



Opened arrester disconnector after temperature cycling and seal pumping test:




检测报告

TEST REPORT

Page 28 of 58

Tested object photos

Short-circuit tests photos:



2# Arrester before short-circuit test (16000A)



2# Arrester after short-circuit test (16000A)

检测报告

TEST REPORT

Page 29 of 58

Tested object photos



3# Arrester before short-circuit test (6000A)



3# Arrester after short-circuit test (6000A)

检测报告

TEST REPORT

Page 30 of 58

Tested object photos



4# Arrester before short-circuit test (3000A)



4# Arrester after short-circuit test (3000A)

检测报告

TEST REPORT

Page 31 of 58

Tested object photos



5# Arrester before short-circuit test (600A)



5# Arrester after short-circuit test (600A)


检测报告

TEST REPORT

Page 32 of 58

Tested object photos

UV light test photos:




Before UV light test

检测报告

TEST REPORT

Page 33 of 58

Tested object photos



After UV light test


检测报告

TEST REPORT

No. DY201020

Page 34 of 58

Short-circuit tests circuit



TM : 试验电源 (Test power supply)

1QF : 保护开关 (Protective switch)

1HK : 合闸开关 (Making switch)

L : 调节电抗 (Reactor)

2QF : 操作开关 (Master breaker)


SP : 试品 (Test specimen)

检测报告

TEST REPORT

Page 35 of 58

(4/10μs)High current impulse withstand and Residual voltage tests circuit	D20-GY0875-YLT1
---	-----------------



AT:voltage regulator

TT:power frequency testing transformer

 R_p :charging protection resistor R_1 :High voltage side resistance of voltage divider for charging protection R_2 :Low voltage side resistance of voltage divider for charging protection $C_1 \sim C_n$:capacitor

g:discharge gap

T₀:test samples R_1' :High voltage side resistance of voltage divider for measurement R_2' :Low voltage side resistance of voltage divider for measurement

CTR:Rogowski Coil

OSO:measurement system


检测报告

TEST REPORT

Page 36 of 58

(1.2/50μs) lightning impulse withstand voltage test circuit

D20-GY0875-YLT2

 C_1 : generator capacitance g_1 : discharge gap R_{S1} : internal series resistance R_{S2} : front resistance R_p : tail resistance C_L : load capacitance Z_1 , Z_2 : voltagedivider impedance T_x : texted object R_F : shunt current resistance Z_c : additional impedance g_2 :Chopping wave gap


检测报告

TEST REPORT

Page 37 of 58

Short-circuit tests oscillograms

D20G-GY0875-S1




检测报告

TEST REPORT

Page 38 of 58

Short-circuit tests oscillograms




检测报告

TEST REPORT

Page 39 of 58

Short-circuit tests oscillograms




检测报告

TEST REPORT

Page 40 of 58

Short-circuit tests oscillograms






检测报告

TEST REPORT

Page 41 of 58




Lightning impulse residual voltage test oscillograms

R₁(10kA)oscillogram No.: L20-GY0875-S01R₂(10kA)oscillogram No.: L20-GY0875-S02R₃(10kA)oscillogram No.: L20-GY0875-S03

检测报告

TEST REPORT

Steep current impulse residual voltage test oscilloscopes







R₁(10kA)oscillogram No.: L20-GY0875-S04R₂(10kA)oscillogram No.: L20-GY0875-S05R₃(10kA)oscillogram No.: L20-GY0875-S06

检测报告

TEST REPORT

Page 43 of 58

Repetitive charge transfer withstand test Typical oscillograms







R₄ 1st test oscillogram No.: L20-GY0875-S07R₄ 20st test oscillogram No.: L20-GY0875-S08R₅ 1st test oscillogram No.: L20-GY0875-S09R₅ 20st test oscillogram No.: L20-GY0875-S10R₆ 1st test oscillogram No.: L20-GY0875-S11R₆ 20st test oscillogram No.: L20-GY0875-S12

检测报告

TEST REPORT

Page 44 of 58

Repetitive charge transfer withstand test Typical oscillograms







R₇ 1st test oscillogram No.: L20-GY0875-S13 R₇ 20st test oscillogram No.: L20-GY0875-S14R₈ 1st test oscillogram No.: L20-GY0875-S15 R₈ 20st test oscillogram No.: L20-GY0875-S16R₉ 1st test oscillogram No.: L20-GY0875-S17 R₉ 20st test oscillogram No.: L20-GY0875-S18

检测报告

TEST REPORT

Page 45 of 58

Repetitive charge transfer withstand test Typical oscillograms



R₁₀ 1st test oscilloscope No.: L20-GY0875-S19R₁₀ 20st test oscilloscope No.: L20-GY0875-S20R₁₁ 1st test oscilloscope No.: L20-GY0875-S21R₁₁ 20st test oscilloscope No.: L20-GY0875-S22R₁₂ 1st test oscilloscope No.: L20-GY0875-S23R₁₂ 20st test oscilloscope No.: L20-GY0875-S24

检测报告

TEST REPORT

Page 46 of 58




Repetitive charge transfer withstand test Typical oscillograms

R₁₃ 1st test oscillogram No.: L20-GY0875-S25 R₁₃ 20st test oscillogram No.: L20-GY0875-S26

检测报告

TEST REPORT







Operating duty test oscillograms

B₅ 1st test oscillogram No.: L20-GY0875-S27B₆ 1st test oscillogram No.: L20-GY0875-S28B₇ 1st test oscillogram No.: L20-GY0875-S29

检测报告

TEST REPORT







Operating duty test oscillograms

B₅ 1st test oscillogram No.: L20-GY0875-S30B₅ 2st test oscillogram No.: L20-GY0875-S31B₆ 1st test oscillogram No.: L20-GY0875-S32B₆ 2st test oscillogram No.: L20-GY0875-S33B₇ 1st test oscillogram No.: L20-GY0875-S34B₇ 2st test oscillogram No.: L20-GY0875-S35

检测报告

TEST REPORT

Power-frequency voltage versus time test oscilloscopes





B₈ 1st test oscilloscope No.: L20-GY0875-S36B₈ 2st test oscilloscope No.: L20-GY0875-S37B₉ 1st test oscilloscope No.: L20-GY0875-S38B₉ 2st test oscilloscope No.: L20-GY0875-S39B₁₀ 1st test oscilloscope No.: L20-GY0875-S40B₁₀ 2st test oscilloscope No.: L20-GY0875-S41

检测报告

TEST REPORT

Page 50 of 58







Power-frequency voltage versus time test oscillograms

B₁₁ 1st test oscillogram No.: L20-GY0875-S42 B₁₁ 2st test oscillogram No.: L20-GY0875-S43B₁₂ 1st test oscillogram No.: L20-GY0875-S44 B₁₂ 2st test oscillogram No.: L20-GY0875-S45

检测报告

TEST REPORT

Disconnecter repetitive charge transfer withstand test Typical oscillograms




T₁ 1st test oscilloscope No.: L20-GY0875-S46 T₁ 20st test oscilloscope No.: L20-GY0875-S47T₂ 1st test oscilloscope No.: L20-GY0875-S48 T₂ 20st test oscilloscope No.: L20-GY0875-S49T₃ 1st test oscilloscope No.: L20-GY0875-S50 T₃ 20st test oscilloscope No.: L20-GY0875-S51

检测报告

TEST REPORT

Page 52 of 58







Disconnecter operating duty test oscilloscopes

B₁₃+T₄ 1st test oscilloscope No.: L20-GY0875-S52B₁₄+T₅ 1st test oscilloscope No.: L20-GY0875-S53B₁₅+T₆ 1st test oscilloscope No.: L20-GY0875-S54

检测报告

TEST REPORT

Disconnecter operating duty test oscilloscopes


B₁₃+T₄ 1st test oscilloscope No.: L20-GY0875-S55B₁₃+T₄ 2st test oscilloscope No.: L20-GY0875-S56B₁₄+T₅ 1st test oscilloscope No.: L20-GY0875-S57B₁₄+T₅ 2st test oscilloscope No.: L20-GY0875-S58B₁₅+T₆ 1st test oscilloscope No.: L20-GY0875-S59B₁₅+T₆ 2st test oscilloscope No.: L20-GY0875-S60

检测报告


TEST REPORT

Page 54 of 58


Lightning impulse residual voltage test oscillograms



6#(10kA)oscillogram No.:L20-GY0875-S61



7#(10kA)oscillogram No.:L20-GY0875-S62






8#(10kA)oscillogram No.:L20-GY0875-S63

检测报告

TEST REPORT

Page 55 of 58


Lightning impulse residual voltage test oscillograms




检测报告

TEST REPORT


Lightning impulse residual voltage test oscillograms



6#(10kA)oscillogram No.:L20-GY0875-S67



7#(10kA)oscillogram No.:L20-GY0875-S68




8#(10kA)oscillogram No.:L20-GY0875-S69

检测报告


TEST REPORT

Page 57 of 58


Lightning impulse residual voltage test oscillograms



6#(10kA)oscillogram No.:L20-GY0875-S70



7#(10kA)oscillogram No.:L20-GY0875-S71



8#(10kA)oscillogram No.:L20-GY0875-S72

检测报告

TEST REPORT

附注:

Notions:

1. 试验地点:

Testing location/ address No.68, XiHu East Road, ShiLong Town, Dongguan City, Guangdong Province, China

2. 委托单位(申请人)地址及邮编:

Address of applicant No.268, Xingye East Street, Xinji Economic Development Zone, Hebei, China

3. 检测环境条件(如适用):

Environmental conditions (if applicable)

温度:

相对湿度:

其它:

Temperature (25.4~33.6) °C,

Humidity 47%~76%,

Other _____

4. 抽样程序(如适用):

Sampling procedure (if applicable) _____

5. 偏离标准方法的说明(如适用):

The interpretation of the deviation (s) from standard method (s) (if applicable) _____

6. 检测结果不确定度说明(如适用):

The interpretation of the measurement uncertainty of the result (s) (if applicable) _____

7. 分包项目及分包方(如适用):

Subcontract items and subcontractor (if applicable) _____



广东产品质量监督检验研究院

GUANGDONG TESTING INSTITUTE OF PRODUCT QUALITY SUPERVISION

Guangdong Testing Institute of Product Quality Supervision (In Short GQI), also called Guangzhou Electrical Safety Testing Institute, Guangdong Testing and Certification Institute, was set up in September, 1983. It is a public institution affiliated to Guangdong Administration for Market Regulation (Administration for Intellectual Property).

GQI is a legal third party institute specializing in product testing, inspection and certification; it is subordinate to Guangdong Administration for Market Regulation (Administration for Intellectual Property); it is a national-level testing and inspecting organization accredited by China National Accreditation Service for Conformity Assessment (CNAS); it is an international CB testing laboratory recognized by International Electro-technical Commission System for Conformity Testing and Certification of Electro-technical Equipment and Components(IECEE); it is the national compulsory CCC testing organization designated by Certification and Accreditation Administration of the People's Republic of China(CNCA).

GQI currently undertakes commitment of 10 national supervision and testing centers, which are:

- ▼ China National Quality Supervision and Testing Center for Safety of Electrical Products China National Quality Supervision and Testing Center for Furniture (Guangdong)
- ▼ China National Quality Supervision and Testing Center for Smart Grid Transmission and Distribution Equipment(CEST)
- ▼ China National Quality Supervision and Testing Center for Paintings and Dopes (Guangdong)
China National Quality Supervision and Testing Center for Food (Guangdong)
- ▼ China National Quality Supervision and Testing Center for Machinery Safety
- ▼ China National Quality Supervision and Testing Center for Fire Fighting Products (Guangdong)
- ▼ China National Quality Supervision and Testing Center for Solar Energy Photovoltaic Products (Guangdong)
- ▼ China National Quality Supervision and Testing Center for Cables and Wires (Guangdong)
China National Quality Supervision and Testing Center for Industrial Robots (Guangdong)